

<b>WinFrog Device Group:</b>	<b>COUNTER</b>
<b>Device Name/Model:</b>	<b>Etisalat Counter CDE</b>
<b>Device Manufacturer:</b>	For interfacing to the CDE (cable drum engine) on the C/S Umm Al Anber
<b>Device Data String(s) Output to WinFrog:</b>	See below
<b>WinFrog Data String(s) Output to Device:</b>	None
<b>WinFrog Data Type(s) and their RAW record</b>	COUNT      492

**DEVICE DESCRIPTION:**

The Etisalat CDE Counter provides a cable speed, count and tension at about 1 Hz. The interface is RS232 serial. Unlike the other Etisalat counters this one does not provide control over the drum's speed.

Note: There are three Etisalat counters; one for the C/S NIWA, named Etisalat Counter, which uses the Parkburn LCE, one for the C/S Umm al Anber, named Etisalat Counter UAA, which uses a Fraser Hydraulic LCE, and this one.

***DEVICE CONFIGURATION INSTRUCTIONS:***

---


**WINFROG I/O DEVICES > EDIT I/O:**

Baud Rate:           (Adjustable) 9600  
Bits Per Character: 8  
Stop Bits:            1  
Parity:                NONE

**WINFROG I/O DEVICES > CONFIGURE DEVICE:**

This device is added to WinFrog from the COUNTER device group and when added, creates one data item: COUNT.

This device must be configured at the I/O Devices level. In the I/O Devices window, highlight the **Etisalat Counter CDE** device, right-click and select Configure Device. The **Etisalat Counter Configuration CDE** dialog box will appear, as seen below.



### Counter Control

Scaling within WinFrog should only be used as a last resort. It is always better to have the cable engine output the correct cable count. Also, only the corrected cable count is recorded in the \*.RAW files.


This scale factor can be applied along the entire length of cable or you can choose to apply the scale factor from a certain cable count onward. Enter the desired cable count from which to start applying the scale factor in the “Apply scale from CC” edit box. An offset can also be added to the cable count from the cable engine; scale is applied first, followed by the addition of the offset. All scale factor applications are accumulative, i.e., all previous scale factors entered are also applied. Only the last application is displayed when the dialog is opened.

To clear all scaling and offsets, select the Clear and reset (1,0,0) checkbox.

Care is required when entering values here, as applying a scale to the current cable count can result in a cable count jump that will adversely affect the cable model. If the cable model is running, apply new scale factor changes to the current count. You will not see an immediate change in the count. All entries should be logged, as the INI and CFG files only record the accumulated effect of all the scale changes.

### **WINFROG VEHICLE > CONFIGURE VEHICLE-DEVICES > DEVICE > EDIT:**

The **Etisalat Counter CDE,COUNT** data item must be edited once it is added to a vehicle’s device list. Highlight the **COUNTER, Etisalat Counter CDE, COUNT** data item in the vehicle’s device list and click the **Edit** button. The **Configure Counter** dialog box appears as seen below.



This dialog has two tabs. The first, **Reference Counters**, does not apply to this counter and should be left at the defaults. The second, **Real-Time Navigation Updates**, enables or disables this device's data from being passed to the vehicle. The three values available from this device are placed into channel one. (Channel one is reserved for product cable and is where the cable model looks for its required data.) Uncheck all remaining values, as this counter does not read them.

You can control the amount of data written to the raw file by changing the value in the interval box.

If another counter is attached to this vehicle you must place its data into another channel. If this is not done, the other device will overwrite the values from this device. For example, if a tow winch counter and load cell is available, this same configuration dialog is used for that device's COUNT data item. Its data must be placed into channel two and all the other boxes left unchecked.

**TELGRAM SPECIFICATION:**

Sent by the cable machinery to WinFrog. If the header ~ is not present the telegram will be rejected.

~ D sss ccccc kkk kkk<LF>

<b>Field</b>	<b>Data</b>
1	Header (tilde) ~ 2 spaces
2	Header D 2 spaces
3	sss Speed in millimetres/sec 2 spaces
4	cccc Cable count in metres 2 spaces
5	kkk Tension in tonnes times 100 (1000kg) 2 spaces
6	kkk Tension in tonnes times 100 (1000kg)
7	Line feed